

## BUILDING SAFETY CERTIFICATE

No. AEE:PWD:SD:AE:SC:2022-23:848-49


Dated: 04/01/2024

Certified that the existing building OOM SHREENIKETHANA TRUST (R) (name of the building or premises) at Near Check Post, Bengaluru-Mysuru Highway, Srirangapatna – 571 438, Mandya District (address) comprised of Ground Floor (basement(s) and First, Second & Third Floor (upper floors) owned/occupied by PARIVARTHANA SCHOOL (name of the Institution) have complied with the Building safety requirements in accordance with National Building code Rules, and verified by the officers concerned of Assistant Executive Engineer, Sub Division, Public Works Department, Srirangapatna (name of Department/Govt.) on 04/01/2024 (date of inspection) in the presence of the Managing Trustee & Dean, Oom Shreenikethana Trust (R), Srirangapatna – 571 438 (name and addresses of the Manager/Secretary or his representative) and that building/premises is fit for occupancy upto classes X with effect from 04/01/2024 for a period of One years in accordance with rule and subject to compliance of the specific conditions as appended.

1. Surface crack & dampness in some part of School & College building was found and instruted to rectify the same within 30 days. If failed to rectify, order of this Safety Certificate will stand cancelled.

\*Strike out whichever is not applicable.

Issued on 04/01/2024 at Office of Assistant Executive Engineer, Sub Division, Srirangapatna by Assistant Executive Engineer

Signature with Seal: Name: J. S. KANTAPPA, M.C.Designation: Assistant Executive EngineerName & Address of Department/Office: No. 6, P.W.D. Sub-Division, Srirangapatna.

(Assistant Engineer &amp; above Officer of concerned Govt. Department Only)


**Note:** This certificate should be signed / issued by Assistant Engineer & above officer or concerned Govt. Department Only.

\*The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.



Principal

Parivarthana School  
Near Check Post, Bengaluru-Mysuru Highway  
SRIRANGAPATNA-571 438, Mandya District



Managing Trustee,  
Oom Shreenikethana Trust (R.),  
Near Old Karnataka Bank,  
Srirangapatna-571 438